



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HANOVER TECHNICAL SPECIFICATIONS.
2. ALL WATER MAIN SHOULD HAVE A MINIMUM DEPTH OF 5' 6" FROM TOP OF PIPE TO FINISH GRADE.
3. SEE DETAIL W-16 FOR TRENCH DETAIL.



DETAIL W-15
TYPICAL UTILITY SEPARATION
(MAIN) DETAIL
 TOWN OF HANOVER
 REV: 06/14 BY: PEK SCALE: NTS