



NOTES:

1. HANOVER RESERVES THE RIGHT TO MODIFY INSULATION BASED ON FIELD CONDITIONS.
2. THE LENGTH OR WIDTH OF INSULATION SHALL EXTEND ONE PIPE DIAMETER BEYOND THE EDGE OF STORM DRAIN IN EACH DIRECTION OR A MINIMUM OF 2' BEYOND THE CENTERLINE OF THE STORM DRAIN.
3. ALL BUTT JOINT SEAMS TO BE OVERLAPPED WITH A 1' PIECE OF INSULATION CENTERED OVER SEAM.



DETAIL W-17
STORM DRAIN CROSSING
OF WATER MAIN
TOWN OF HANOVER
REV: 06/14 BY: PEK SCALE: NTS