



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HANOVER TECHNICAL SPECIFICATIONS.
2. ALL PIPE SHOULD HAVE A MINIMUM DEPTH OF 5' 6" FROM TOP OF PIPE TO FINISH GRADE.
3. SERVICE ENTRANCE SHALL BE MADE IN THE FRONT OR SIDE OF BUILDING.
4. SERVICE ENTRANCE MADE IN REAR OF HOUSE WILL NOT BE ACCEPTED UNLESS PREVIOUSLY APPROVED BY HANOVER
5. SERVICE ENTRANCE LOCATION WILL BE DETERMINED BY THE HANOVER REPRESENTATIVE ON SITE.
6. IF SERVICE IS TAPPED OFF A FIRE SERVICE, THEN SEE DETAIL W-2.



DETAIL W-14  
TYPICAL UTILITY SEPARATION  
(SERVICE) DETAIL

TOWN OF HANOVER  
REV: 06/14 BY: PEK SCALE: NTS