



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HANOVER TECHNICAL SPECIFICATIONS.
2. ALL PIPE SHOULD HAVE A MINIMUM DEPTH OF 5' 6" FROM TOP OF PIPE TO FINISH GRADE.
3. SEE DETAIL W-12 FOR CROSS-SECTIONAL VIEW.



DETAIL W-11
TYPICAL LARGE SERVICE AND/OR
TAPPING SLEEVE DETAIL
TOWN OF HANOVER
REV: 06/14 BY: PEK SCALE: NTS