



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HANOVER TECHNICAL SPECIFICATIONS.
2. ALL PIPE SHOULD HAVE A MINIMUM DEPTH OF 5' FROM TOP OF PIPE TO FINISH GRADE.



DETAIL W-6A
TYPICAL END OF MAIN
INSTALLATION
 TOWN OF HANOVER
 REV: 6/14 BY: PEK SCALE: NTS