



NOTES:

1. ALL MATERIALS AND INSTALLATION PROCEDURES WILL CONFORM TO HANOVER TECHNICAL SPECIFICATIONS.
2. ALL PIPE SHOULD HAVE A MINIMUM DEPTH OF 5' 6" FROM TOP OF PIPE TO FINISH GRADE.



DETAIL W-7
TYPICAL END OF MAIN
 INSTALLATION
 TOWN OF HANOVER
 REV: 06/14 BY: PEK SCALE: NTS